

## REPORT- BEPU Building Utility Performance

WEATHER FILE- EPW INCH'ON,-,KOR

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1 ELECTRICITY													
KWH	483759.	0.	160667.	0.	832.	464.	22732.	130753.	0.	0.	0.	65254.	-1299930.
EM2 ELECTRICITY													
KWH	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	-2164392.
FM1 NATURAL-GAS													
THERM	127382.	0.	51847.	826.	23421.	370.	26072.	121926.	0.	0.	9482.	3846.	570524.
FUEL USED TO GENERATE ELECTRICITY CONSUMED OFFSITE =						205353.	THERM						

TOTAL ELECTRICITY	-3464322. KWH	-5.160 KWH	/SQFT-YR GROSS-AREA	-5.160 KWH	/SQFT-YR NET-AREA
TOTAL NATURAL-GAS	570524. THERM	0.850 THERM	/SQFT-YR GROSS-AREA	0.850 THERM	/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 1.8  
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.