

REPORT- BEPU Building Utility Performance

WEATHER FILE- New York CityNY TMY2

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1 ELECTRICITY													
KWH	320542.	0.	148979.	17975.	74499.	734.	26459.	0.	0.	0.	0.	0.	589189.
FM1 NATURAL-GAS													
THERM	0.	0.	0.	2247.	0.	0.	0.	0.	0.	0.	7730.	0.	9977.

TOTAL ELECTRICITY 589189. KWH 9.994 KWH /SQFT-YR GROSS-AREA 9.994 KWH /SQFT-YR NET-AREA  
 TOTAL NATURAL-GAS 9977. THERM 0.169 THERM /SQFT-YR GROSS-AREA 0.169 THERM /SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.0  
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.