

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR
EML ELECTRICITY											
KWH	179966.	5627.	-nan	-nan	-nan	0.	-nan	28409.	0.	254.	-nan
FML NATURAL-GAS											
THERM	0.	0.	-nan	7851.	-nan	0.	0.	0.	0.	0.	0.

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 47.4
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

NOTE: RESIDUAL ENERGY IN THERMAL STORAGE DEVICES IS INCLUDED IN THE TOTALS, BUT NOT IN THE END-USE CATEGORIES.