


Typical Office Floor



SPACES	ORIGINS		SPACE-COORDINATES				SPACE-COORDINATES				SPACE-COORDINATES				AREAS and % Areas		
	X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Areas	EXT-INT	%
Ext-N	180	120	0	120	15	105	165	105	180	120					2,475	8,100	37.5
Ext-E	180	0	180	120	165	105	165	15	180	0					1,575		
Ext-S	0	0	180	0	165	15	15	15	0	0					2,475		
Ext-W	0	120	0	0	15	15	15	105	0	120					1,575		
Int-NW	165	105	15	105	15	15	35	35	35	85	145	85	165	105	4,000	8,000	37.0
Int-SE	15	15	165	15	165	105	145	85	145	35	35	35	15	15	4,000		
Cor-NW	35	35	90	35	90	85	35	85	35	35					2,750	5,500	25.5
Cor-SE	90	35	145	35	145	85	90	85	90	35					2,750		
															21,600	21,600	100

Floor Polygons served by OAU-SE and OAU-NW

Floor Polygons served by AHU-SE and AHU-NW

NW	180	120	0	120	0	0	35	35	90	35	90	85	145	85	180	120	8,050
SE	0	0	180	0	180	120	145	85	90	85	90	35	35	35	0	0	8,050

Exterior-Wall Origin is Lower Left Corner (LLC) looking at

Wall from the Outside. Draw Space Outlines Counter-Clockwise

GENERAL OFFICES

Area/Floor = 16,100 sf
 Occupancy = 150 sf/Person
 Lighting = 1.3 W/sf
 Equipment = 1.0 W/sf
 Outdoor-Air = 20 cfm/Person
 Systems = AHU-SE & AHU-NW
 (per Floor - OA from OAU)

SERVICE CORE (Average)

Area/Floor = 5,500 sf
 Occupancy = 300 sf/Person
 Lighting = 0.5 W/sf
 Equipment = 0.5 W/sf
 Outdoor-Air = 15 cfm/Person
 Exhaust = 2,000 cfm
 Systems = OAU-SE & OAU-NW
 (Central 100% OA - All Floors)

CORE Areas


	Area sf	%
1. Elevators	600	8.8
2. Elec+Tel Closets	300	
3. Mech Rms+Shafts	1,000	
4. Toilets	600	4.2
5. Stairs	300	
Total 1 - 5	2800	
1. Lobby	1,200	12.5
2. Corridors	1,500	

SPACES	Areas	AHU-sf	SYSTEM
Ext-N	2,475	8,050	AHU-NW
Ext-W	1,575		
Int-NW	4,000		
Ext-S	2,475	8,050	AHU-SE
Ext-E	1,575		
Int-SE	4,000		
Cor-NW	2,750	2,750	OAU-NW
Cor-SE	2,750	2,750	OAU-SE
	21,600		

THERMAL ZONES

Exterior Walls and Space Origins

Typical Office Floor





LOADS (LS-A) and SYSTEMS (SV-A) Results from eQUEST/DOE2.2 Reports

SPACE NAME	SUMMER COOLING (from LS-A)			WINTER HEATING (from LS-A)			Sytm (SV-A)	
	Kbtu/h	Peak-Time	OA-DB/WB	Kbtu/h	Peak-Time	OA-DB/WB	Total	
SE-Floor Ceiling Plnm	5	AUG 27 3 PM	88.F 80.F	13	JAN 6 7 AM	-18.F -18.F	0	AHU-
South Perim Spc (G.S1)	131	OCT 7 2 PM	75.F 59.F	74	DEC 31 4 AM	-20.F -20.F	4,336	SE
East Perim Spc (G.E2)	82	JUN 23 10 AM	81.F 66.F	48	DEC 31 4 AM	-20.F -20.F	3,903	10,539
SE Inter Spc (G.C5)	24	MAY 27 5 PM	94.F 75.F	0	0.F 0.F		2,300	
NW-Floor Ceiling Plnm	2	JUN 29 12 NOON	87.F 75.F	8	JAN 6 7 AM	-18.F -18.F	0	AHU-
North Perim Spc (G.N3)	51	MAY 27 4 PM	95.F 76.F	73	JAN 4 11 PM	-13.F -14.F	2,229	NW
West Perim Spc (G.W4)	84	JUN 29 7 PM	89.F 75.F	49	DEC 31 4 AM	-20.F -20.F	4,388	8,917
NW Inter Spc (G.C6)	24	MAY 27 5 PM	94.F 75.F	0	0.F 0.F		2,300	
SE Core Spc (G.C7)	10	MAY 27 5 PM	94.F 75.F	0	DEC 31 12 MDNT	-21.F -21.F	949	OA-SE
NW Core Spc (G.C8)	10	MAY 27 5 PM	94.F 75.F	0	DEC 31 12 MDNT	-21.F -21.F	949	OA-NW
SUM	5,484			3,452				
BUILDING PEAK	3,787	OCT 7 4 PM	80.F 62.F	3,165	DEC 31 4 AM	-20.F -20.F		


	Flr-Area	People	OA-Ratio	CFM/Flr	OA-CFM
AHU-SE	9,425	48	0.085	11,093	943
AHU-NW	9,425	48	0.100	9,388	939
OAU-SE	2,750	9	0.145	949	138
OAU-NW	2,750	9	0.145	949	138

AHU Floor Areas adjusted for Plenum-A
OAU must have at least 1 Zone (Core Assigned)
OAU (100% OA Unit) supplies OA to AHU
OAU cfm does not add up to OA for AHU
Outdoor CFMs do not make sense





High-Rise Multi-use Commercial Building

Typical Office Floors - 11 thru 33 except 22
Distributed CHWS & CHWR shown

REPORT- SV-A System Design Parameters for OAU-SE-Core WEATHER FILE- Minneapolis MN TMY2

FLOOR	OUTSIDE	COOLING	HEATING	COOLING	HEATING	HEAT PUMP				
SYSTEM ALTITUDE	AREA	MAX	AIR CAPACITY	SENSIBLE	CAPACITY	EIR				
TYPE FACTOR (SQFT)	PEOPLE	RATIO (KBTU/HR)	(SHR)	(KBTU/HR)	(BTU/BTU)	(BTU/BTU)				
						(KBTU/HR)				
VAVS	1.000	35750.0	119.	0.145	527.973	0.585	-892.772	0.000	0.000	0.000

DIVERSITY	POWER	FAN	STATIC	TOTAL	MECH	MAX FAN	MIN FAN				
FAN CAPACITY	FACTOR	DEMAND	DELTA-T	PRESSURE	EFF	EFF	FAN				
TYPE (CFM)	(FRAC)	(KW)	(F) (IN-WATER)	(FRAC)	(FRAC)	PLACEMENT	CONTROL				
							(FRAC)				
SUPPLY	12334.	1.00	10.133	2.54	3.5	0.50	0.55	BLOW-THRU	SPEED	1.00	0.30

SUPPLY	EXHAUST	MINIMUM	OUTSIDE	COOLING	EXTRACTION	HEATING	ADDITION				
ZONE	FLOW	FLOW	FAN	FLOW	AIR FLOW	CAPACITY	SENSIBLE				
NAME	(CFM)	(CFM)	(KW)	(FRAC)	(CFM)	(KBTU/HR)	(FRAC)				
							(KBTU/HR)				
OFC SE Core Zn (G.C7)	949.	0.	0.000	1.000	138.	0.00	0.00	22.54	-95.80	-67.63	13.

REPORT- SV-A System Design Parameters for AHU-SE-Zones WEATHER FILE- Minneapolis MN TMY2

FLOOR	OUTSIDE	COOLING	HEATING	COOLING	HEATING	HEAT PUMP				
SYSTEM ALTITUDE	AREA	MAX	AIR CAPACITY	SENSIBLE	CAPACITY	EIR				
TYPE FACTOR (SQFT)	PEOPLE	RATIO (KBTU/HR)	(SHR)	(KBTU/HR)	(BTU/BTU)	(BTU/BTU)				
						(KBTU/HR)				
VAVS	1.000	245050.0	625.	0.085	5913.182	0.591	-4250.368	0.000	0.000	0.000

DIVERSITY	POWER	FAN	STATIC	TOTAL	MECH	MAX FAN	MIN FAN				
FAN CAPACITY	FACTOR	DEMAND	DELTA-T	PRESSURE	EFF	EFF	FAN				
TYPE (CFM)	(FRAC)	(KW)	(F) (IN-WATER)	(FRAC)	(FRAC)	PLACEMENT	CONTROL				
							(FRAC)				
SUPPLY	144210.	1.00	203.112	4.36	6.0	0.50	0.55	BLOW-THRU	SPEED	1.00	0.30
RETURN	144210.	1.00	50.778	1.09	1.5	0.50	0.56	RETURN	SPEED	1.00	0.30

SUPPLY	EXHAUST	MINIMUM	OUTSIDE	COOLING	EXTRACTION	HEATING	ADDITION				
ZONE	FLOW	FLOW	FAN	FLOW	AIR FLOW	CAPACITY	SENSIBLE				
NAME	(CFM)	(CFM)	(KW)	(FRAC)	(CFM)	(KBTU/HR)	(FRAC)				
							(KBTU/HR)				
OFC South Perim Zn (G.S1)	4336.	0.	0.000	0.300	330.	0.00	0.00	103.01	-131.34	-92.71	13.
OFC East Perim Zn (G.E2)	3903.	0.	0.000	0.300	210.	0.00	0.00	92.73	-118.23	-83.46	13.
OFC SE Inter Zn (G.C5)	2300.	0.	0.000	0.300	400.	0.00	0.00	54.65	-69.68	-49.18	13.
OFC AHU-SE Plenum Zn (G.S	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	13.

System	Enterg	Enterg	AIR TEMP	AIR TEMP	TOT HTG	TOT CLG	TOT SYST	MOISTURI	OUTSIDE
AHU- SE	Htg Coil F	Clg Coil F	ENTERNG F	RETURN F	COIL PWR BTU/HR	COIL PWR BTU/HR	FLOWRATE CFM	CHANGE LB	TOT FLOW FRAC.OR
	----(1	----(2)	----(3)	----(4)	----(5)	----(6)	---(17)	---(38)	---(39)
21-Jan								Added	
1 21 7	61.3	61.3	60.9	66.8	4,226	0	12334	12.6	0.145
1 21 8	94.3	94.3	63	69.3	413,801	0	12334	12.6	0.145
1 21 9	82.6	82.6	66.4	73.3	213,648	0	12334	0	0.145
1 21 10	75	75	67.9	74.3	92,769	0	12334	0	0.145
1 21 11	17.6	65	65	74.8	0	0	12334	0	0.209
1 21 12	19.6	65	65	74.9	0	0	12334	0	0.216
1 21 13	23.6	65	65	75	0	0	12334	0	0.234
1 21 14	21.6	65	65	75.2	0	0	12334	0	0.228
1 21 15	20.6	64.5	64.5	75.3	0	0	12334	0	0.234
1 21 16	19.6	64	64	75.4	0	0	12334	0	0.24
1 21 17	16.6	63.6	63.6	75.4	0	0	12334	0	0.234
1 21 18	14.6	64.3	64.3	75.3	0	0	12334	0	0.216
1 21 19	11.6	65	65	75.2	0	0	12334	0	0.194
21-Jul								Removed	
7 21 6	79.9	65	79.7	77.3	0	239,899	12334	46.1	0.145
7 21 7	53.6	65	79.5	76.8	0	240,586	12334	51.8	0.145
7 21 8	53.4	65	80.0	77.0	0	268,758	12334	71.6	0.145
7 21 9	54.4	65	80.2	76.9	0	272,459	12334	73.0	0.145
7 21 10	54.6	65	80.2	76.8	0	271,791	12334	72.0	0.145
7 21 11	54.6	65	80.5	76.7	0	265,476	12334	63.6	0.145
7 21 12	54.2	65	80.6	76.6	0	256,677	12334	54.7	0.145
7 21 13	53.7	65	80.4	76.6	0	259,000	12334	58.6	0.145
7 21 14	53.8	65	80.3	76.6	0	246,937	12334	48.9	0.145
7 21 15	53.3	65	80.2	76.7	0	242,534	12334	46.3	0.145
7 21 16	53.1	65	79.9	76.7	0	236,921	12334	44.5	0.145
7 21 17	53.0	65	79.6	76.5	0	219,240	12334	30.8	0.145
7 21 18	53.0	65	79.2	76.4	0	207,405	12334	25.0	0.145