



**Electric Consumption (kWh x000)**

|               | Jan         | Feb         | Mar         | Apr         | May         | Jun         | Jul         | Aug         | Sep         | Oct         | Nov         | Dec         | Total        |
|---------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Space Cool    | -           | -           | -           | 0.04        | 0.54        | 1.58        | 1.75        | 1.91        | 0.91        | 0.32        | 0.04        | -           | 7.08         |
| Heat Reject.  | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -            |
| Refrigeration | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -            |
| Space Heat    | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -            |
| HP Supp.      | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -            |
| Hot Water     | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -            |
| Vent. Fans    | 0.26        | 0.26        | 0.31        | 0.30        | 0.27        | 0.30        | 0.28        | 0.30        | 0.28        | 0.27        | 0.27        | 0.28        | 3.38         |
| Pumps & Aux.  | 0.24        | 0.23        | 0.21        | 0.10        | 0.03        | -           | -           | -           | 0.01        | 0.07        | 0.18        | 0.22        | 1.30         |
| Ext. Usage    | 0.23        | 0.18        | 0.20        | 0.19        | 0.14        | 0.13        | 0.14        | 0.22        | 0.21        | 0.22        | 0.22        | 0.23        | 2.31         |
| Misc. Equip.  | 2.72        | 2.62        | 3.08        | 2.95        | 2.81        | 2.95        | 2.89        | 2.99        | 2.86        | 2.81        | 2.77        | 2.90        | 34.34        |
| Task Lights   | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -           | -            |
| Area Lights   | 1.76        | 1.75        | 2.11        | 2.02        | 1.85        | 2.02        | 1.94        | 2.02        | 1.93        | 1.85        | 1.84        | 1.94        | 23.03        |
| <b>Total</b>  | <b>5.21</b> | <b>5.03</b> | <b>5.91</b> | <b>5.60</b> | <b>5.62</b> | <b>6.98</b> | <b>7.00</b> | <b>7.44</b> | <b>6.22</b> | <b>5.53</b> | <b>5.33</b> | <b>5.57</b> | <b>71.44</b> |

**Gas Consumption (Btu x000,000)**

|               | Jan          | Feb          | Mar          | Apr         | May         | Jun         | Jul         | Aug         | Sep         | Oct         | Nov          | Dec          | Total         |
|---------------|--------------|--------------|--------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|--------------|---------------|
| Space Cool    | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| Heat Reject.  | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| Refrigeration | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| Space Heat    | 27.11        | 23.51        | 21.46        | 6.49        | 0.48        | 0.06        | -           | -           | 0.01        | 0.76        | 9.77         | 19.63        | 109.27        |
| HP Supp.      | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| Hot Water     | 0.70         | 0.72         | 0.86         | 0.81        | 0.69        | 0.70        | 0.62        | 0.62        | 0.59        | 0.59        | 0.63         | 0.71         | 8.23          |
| Vent. Fans    | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| Pumps & Aux.  | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| Ext. Usage    | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| Misc. Equip.  | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| Task Lights   | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| Area Lights   | -            | -            | -            | -           | -           | -           | -           | -           | -           | -           | -            | -            | -             |
| <b>Total</b>  | <b>27.80</b> | <b>24.22</b> | <b>22.32</b> | <b>7.30</b> | <b>1.17</b> | <b>0.75</b> | <b>0.62</b> | <b>0.62</b> | <b>0.60</b> | <b>1.35</b> | <b>10.40</b> | <b>20.34</b> | <b>117.49</b> |