

Notes	No ERV		ERV VAV				
		ERV on when fans on, Float control	OA Exhaust DH, Float	Mixed Air Reset; Modulate HX	Mixed Air Reset; Trim Economizer	OA Exhaust DT, Float	OA Exhaust DT, Mixed Air Reset; Modulate HX
Space Cooling	31.89	51.11	51.36	31.13	31.09	51.89	31.58
Vent. Fans	13.87	17.08	16.72	14.38	14.37	16.76	14.29
Pumps & Aux.	9.65	15.52	14.8	10.33	11.33	14.77	10.10
Misc.	46.27	46.27	46.27	46.27	46.27	46.27	46.27
Area Lights	90.47	90.47	90.47	90.47	90.47	90.47	90.47
<b>Total</b>	192.15	220.45	219.62	192.58	193.53	220.16	192.71
Space Heating	285.94	232.08	232.08	282.98	286.97	232.08	282.98
Hot Water	35.99	35.98	35.98	35.99	35.99	35.98	35.99
<b>Total</b>	321.93	268.06	268.06	318.97	322.96	268.06	318.97
<b>Total Energy</b>	1,031,394	1,076,438	1,073,450	1,029,819	1,037,449	1,075,394	1,030,287
<b>% Savings</b>	N/A	<b>-4.37%</b>	<b>-4.08%</b>	0.15%	<b>-0.59%</b>	<b>-4.27%</b>	0.11%

Notes	No ERV		ERV SZ			
		ERV on when fans on, Float control	OA Exhaust DH, Float	Mixed Air Reset; Modulate HX	Mixed Air Reset; Trim Economizer	OA Exhaust DT, Float
Space Cooling	35.45	59.91	60.01	35.21	35.15	60.48
Space Cooling Jan	0.73	1.35	1.35	0.75	0.73	1.35
Space Cooling July	10.02	10.09	10.28	9.76	9.46	10.35
Vent. Fans	95.15	99.8	99.23	96.28	96.29	99.24
Pumps & Aux.	12.22	18.09	17.37	13.01	13.65	17.38
Misc.	46.27	46.27	46.27	46.27	46.27	46.27
Area Lights	90.47	90.47	90.47	90.47	90.47	90.47
<b>Total</b>	279.56	314.54	313.35	281.24	281.83	313.84
Space Heating	230.27	105.38	105.38	179.88	317.51	105.38
Hot Water	35.96	35.94	35.94	35.96	35.96	35.94
<b>Total</b>	266.23	141.32	141.32	215.84	353.47	141.32
<b>Total Energy</b>	1,287,304	1,281,444	1,277,160	1,240,187	1,387,519	1,278,924
<b>% Savings</b>	N/A	0.46%	0.79%	3.66%	<b>-7.78%</b>	0.65%