

Appendix G – Addendum “cr”

- **G3.1.2.3- Unmet Load Hours**

- ▶ Clarified definition of unmet load hours and added definition for temperature control throttling range

unmet load hour: an hour in which one or more zones is outside of the thermostat setpoint plus or minus one half of the *temperature control throttling range*. *Any hour with one or more zones with an unmet cooling load or unmet heating load is defined as an unmet load hour.*

temperature control throttling range: the number of degrees that room temperature must change in order to go from full heating to no heating or from full cooling to no cooling.

- ▶ Removes the requirement that unmet load hours in the *proposed design* cannot exceed unmet load hours in the *baseline design* by more than 50 hours.