

MONTH	S I T E E N E R G Y												* SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	-418.8	0.0	7.1	0.0	0.0	0.0	0.0	628.5	1.1	0.0	628.5	652.6	700.8
FEB	-365.9	0.0	6.4	0.0	0.0	0.0	0.0	551.4	1.0	0.0	551.4	573.1	616.4
MAR	-321.8	0.0	7.2	0.0	0.0	0.0	0.0	502.4	0.9	0.0	502.4	527.2	576.6
APR	-211.2	0.0	6.9	0.0	0.0	0.0	0.1	356.4	0.7	0.0	356.4	379.9	426.9
MAY	-108.9	0.0	7.3	0.0	0.0	0.0	0.5	226.5	0.6	0.0	226.5	251.3	301.0
JUN	-55.0	0.0	7.2	0.0	0.0	0.0	1.3	154.1	0.5	0.0	154.1	178.6	227.8
JUL	-41.8	0.0	7.4	0.0	0.0	0.0	1.6	139.7	0.5	0.0	139.7	165.1	215.9
AUG	-62.2	0.0	7.6	0.0	0.0	0.0	1.0	166.1	0.5	0.0	166.1	191.9	243.7
SEP	-115.6	0.0	7.0	0.0	0.0	0.0	0.3	232.6	0.6	0.0	232.6	256.4	304.0
OCT	-216.3	0.0	7.2	0.0	0.0	0.0	0.1	365.8	0.7	0.0	365.8	390.4	439.5
NOV	-322.5	0.0	7.2	0.0	0.0	0.0	0.0	500.6	0.9	0.0	500.6	525.3	574.8
DEC	-378.6	0.0	7.3	0.0	0.0	0.0	0.0	576.1	1.0	0.0	576.1	601.1	651.2
TOTAL	-2618.6	0.0	85.8	0.0	0.0	0.0	5.0	4400.1	8.9	0.0	4400.1	4692.9	5278.6