



# Room Checksums

By CANNONDESIGN

## 115 ANTE ROOM

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES		
Peaked at Time:		Mo/Hr: 7 / 13			Mo/Hr: 7 / 15		Mo/Hr: Heating Design										
Outside Air:		OADB/WB/HR: 93 / 78 / 126			OADB: 95		OADB: 3										
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent	Space Sens	Tot Sens	Percent	SADB	Cooling	Heating			
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h							
<b>Envelope Loads</b>																	
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	0	55.0	70.0			
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	0	73.0	70.0			
Roof Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	0	74.2	70.0			
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	0	78.5	40.8			
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0.0	0.0			
Wall Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0.0	0.0			
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0.0	0.0			
Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0.0	0.0			
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0.0	0.0			
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0.0	0.0			
Sub Total ==>	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0.0	0.0			
<b>Internal Loads</b>																	
Lights	499	125	624	17	499	27	0	0.00	0	0	0.00	0	0	0			
People	415	0	415	11	208	11	0	0.00	0	0	0.00	0	0	0			
Misc	1,134	0	1,134	31	1,134	62	0	0.00	0	0	0.00	0	0	0			
Sub Total ==>	2,049	125	2,174	60	1,841	100	0	0.00	0	0	0.00	0	0	0			
<b>Ceiling Load</b>																	
Ventilation Load	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0	0			
Adj Air Trans Heat	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0	0			
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0	0			
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0	0			
Exhaust Heat	0	-28	-28	-1	0	0	0	0.00	0	0	0.00	0	0	0			
Sup. Fan Heat	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0	0			
Ret. Fan Heat	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0	0			
Duct Heat Pkup	0	-307	0	0	0	0	0	0.00	0	0	0.00	0	0	0			
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0	0			
Supply Air Leakage	0	0	0	0	0	0	0	0.00	0	0	0.00	0	0	0			
Grand Total ==>	2,049	-210	3,632	100.00	1,841	100.00	0	0.00	0	-1,912	100.00	0	0.8	5.0/1000 ft²			

Supply & Return are equal as they should be

AIRFLOWS		
	Cooling	Heating
Diffuser	94	39
Terminal	94	39
Main Fan	94	39
Sec Fan	0	0
Nom Vent	21	17
AHU Vent	21	17
Infil	0	0
MinStop/Rh	39	39
Return	94	39
Exhaust	21	17
Rm Exh	0	0
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	22.7	43.5
cfm/ft²	0.56	0.24
cfm/ton	309.35	
ft²/ton	549.00	
Btu/hr-ft²	21.86	-11.51

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR			Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg			
ton	MBh	MBh	cfm	°F °F	°F °F	gr/lb		ft² (%)		MBh	cfm	°F	°F	°F			
Main Clg	0.3	3.6	2.4	94 78.5	64.8 71.7	52.0 51.6	57.4	Floor	166	-0.8	39	52.0	70.0				
Aux Clg	0.0	0.0	0.0	0 0.0	0.0 0.0	0.0 0.0	0.0	Part	0	0.0	0	0.0	0.0				
Opt Vent	0.0	0.0	0.0	0 0.0	0.0 0.0	0.0 0.0	0.0	Int Door	0	-1.1	21	2.8	52.0				
								ExFlr	0	-0.8	39	52.0	70.0				
<b>Total</b>	<b>0.3</b>	<b>3.6</b>						Roof	0	0.0	0	0.0	0.0				
								Wall	0	0.0	0	0.0	0.0				
								Ext Door	0	0.0	0	0.0	0.0				
										<b>Total</b>	<b>-1.9</b>						

# Room Checksums

By CANNONDESIGN

## 116 CONTAINMENT SUITE

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK			TEMPERATURES		
Peaked at Time:		Mo/Hr: 7 / 13			Mo/Hr: 7 / 15		Mo/Hr: Heating Design			Cooling			Heating
Outside Air:		OADB/WB/HR: 93 / 78 / 126			OADB: 95		OADB: 3			SADB	55.0	72.0	
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent	Return <td>75.0</td> <td>72.0</td> <td></td>	75.0	72.0		
Btu/h	Btu/h	Btu/h		Btu/h		Space Sens	Tot Sens	Of Total (%)	Ret/OA <td>75.0</td> <td>72.0</td> <td></td>	75.0	72.0		
Envelope Loads													
Skylite Solar	0	0	0	0	0	0	0	0.00	Fn MtrTD	0.0	0.0		
Skylite Cond	0	0	0	0	0	0	0	0.00	Fn BidTD	0.0	0.0		
Roof Cond	0	0	0	0	0	0	0	0.00	Fn Frict	0.0	0.0		
Glass Solar	0	0	0	0	0	0	0	0.00					
Glass/Door Cond	0	0	0	0	0	0	0	0.00					
Wall Cond	0	0	0	0	0	0	0	0.00					
Partition/Door	0	0	0	0	0	0	0	0.00					
Floor	0	0	0	0	0	0	0	0.00					
Adjacent Floor	0	0	0	0	0	0	0	0.00					
Infiltration	0	0	0	0	0	0	0	0.00					
Sub Total ==>	0	0	0	0	0	0	0	0.00					
Internal Loads													
Lights	1,813	0	1,813	18	1,813	32	0	0.00					
People	531	0	531	5	266	5	0	0.00					
Misc	3,626	0	3,626	36	3,626	64	0	0.00					
Sub Total ==>	5,970	0	5,970	60	5,705	100	0	0.00					
Ceiling Load													
Ventilation Load	0	0	4,017	40	0	0	0	81.58					
Adj Air Trans Heat	0	0	0	0	0	0	0	0					
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00					
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00					
Exhaust Heat	0	0	0	0	0	0	-767	18.43					
Sup. Fan Heat	0	0	0	0	0	0	0	0.00					
Ret. Fan Heat	0	0	0	0	0	0	0	0.00					
Duct Heat Pkup	0	-856	0	0	0	0	0	0.00					
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00					
Supply Air Leakage	0	0	0	0	0	0	0	0.00					
Grand Total ==>	5,970	-856	9,987	100.00	5,705	100.00	0	-4,163	100.00				

Room exhaust is greater than the supply air but it isn't 100 CFM greater like it should be

AIRFLOWS		
	Cooling	Heating
Diffuser	261	103
Terminal	261	103
Main Fan	261	103
Sec Fan	0	0
Nom Vent	59	45
AHU Vent	59	45
Infil	0	0
MinStop/Rh	103	103
Return	0	0
Exhaust	0	0
Rm Exh	278	135
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	22.7	43.5
cfm/ft²	0.49	0.19
cfm/ton	313.73	
ft²/ton	638.26	
Btu/hr-ft²	18.80	-10.24
No. People	1.1	2.0/1000 ft²

COOLING COIL SELECTION										
	Total Capacity ton	Capacity MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F °F		Leave DB/WB/HR °F °F gr/lb			
Main Clg	0.8	10.0	6.9	261	79.1	65.0	71.7	52.0	51.9	58.8
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
<b>Total</b>	<b>0.8</b>	<b>10.0</b>								

AREAS		
	Gross Total	Glass ft² (%)
Floor	531	
Part	0	
Int Door	0	
ExFlr	0	
Roof	0	0
Wall	0	0
Ext Door	0	0

HEATING COIL SELECTION				
	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F
Main Htg	-2.3	103	52.0	72.0
Aux Htg	0.0	0	0.0	0.0
Preheat	-3.2	59	2.8	52.0
Reheat	-2.3	103	52.0	72.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
<b>Total</b>	<b>-5.4</b>			

# Room Checksums

By CANNONDESIGN

## 196 CIRCULATION

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES				
Peaked at Time:		Mo/Hr: 7 / 13			Mo/Hr: 7 / 15		Mo/Hr: Heating Design						Cooling			Heating			
Outside Air:		OADB/WB/HR: 93 / 78 / 126			OADB: 95		OADB: 3						SADB	55.0	70.0	Ra Plenum	73.0	70.0	
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent	Space Sens	Tot Sens	Of Total (%)	Ret/OA <td>76.0</td> <td>70.0</td> <th>Fn MtrTD <td>0.0</td> <td>0.0</td> </th>	76.0	70.0	Fn MtrTD <td>0.0</td> <td>0.0</td>	0.0	0.0		
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Fn BidTD	0.0	0.0	Fn Frict	0.0	0.0		
<b>Envelope Loads</b>					<b>Envelope Loads</b>					<b>Envelope Loads</b>					<b>AIRFLOWS</b>				
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Diffuser	89	89	Terminal	89	89		
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Main Fan	89	89	Sec Fan	0	0		
Roof Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Nom Vent	20	39	AHU Vent	20	39		
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Infil	0	0	MinStop/Rh	89	89		
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Return	89	89	Exhaust	20	39		
Wall Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Rm Exh	0	0	Auxiliary	0	0		
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00	Leakage Dwn	0	0	Leakage Ups	0	0		
Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	<b>ENGINEERING CKS</b>							
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	% OA	22.7	43.5					
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00	cfm/ft <sup>2</sup>	0.17	0.17					
Sub Total ==>	0	0	0	0	0	0	0	0.00	0	0	0.00	cfm/ton	268.86						
<b>Internal Loads</b>					<b>Internal Loads</b>					<b>Internal Loads</b>					ft <sup>2</sup> /ton	1,613.18			
Lights	1,160	290	1,450	37	1,160	67	0	0.00	0	0	0.00	Btu/hr-ft <sup>2</sup>	7.44	-7.17					
People	0	0	0	0	0	0	0	0.00	0	0	0.00	No. People	0.0	0.0/1000 ft <sup>2</sup>					
Misc	0	0	0	0	0	0	0	0.00	0	0	0.00								
Sub Total ==>	1,160	290	1,450	37	1,160	67	0	0.00	0	0	0.00								
<b>Ceiling Load</b>					<b>Ceiling Load</b>					<b>Ceiling Load</b>									
Ventilation Load	0	0	1,406	36	0	0	0	0.00	0	-2,827	74.19								
Adj Air Trans Heat	0	0	0	0	0	0	0	0.00	0	0	0								
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00								
Ov/Undr Sizing	1,161	-66	1,161	29	580	33	0	0.00	0	0	0.00								
Exhaust Heat	0	-66	-66	-2	0	0	0	0.00	0	0	0.00								
Sup. Fan Heat	0	0	0	0	0	0	0	0.00	0	-984	25.81								
Ret. Fan Heat	0	0	0	0	0	0	0	0.00	0	0	0.00								
Duct Heat Pkup	0	-290	0	0	0	0	0	0.00	0	0	0.00								
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00								
Supply Air Leakage	0	0	0	0	0	0	0	0.00	0	0	0.00								
<b>Grand Total ==&gt;</b>	<b>2,321</b>	<b>-66</b>	<b>3,951</b>	<b>100.00</b>	<b>1,741</b>	<b>100.00</b>	<b>0</b>	<b>0.00</b>	<b>0</b>	<b>-3,810</b>	<b>100.00</b>								

Supply & Return are equal, the 100 CFM transfer air through the ante room into the containment suite isn't accounted for

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR		Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg				
ton	MBh	MBh	cfm	°F °F	gr/lb	°F °F	gr/lb	ft <sup>2</sup>	(%)	MBh	cfm	°F	°F				
Main Clg	0.3	4.0	3.0	89	79.8	65.2	71.7	52.0	49.9	51.2	Floor	531	Main Htg	-1.7	89	52.0	70.0
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0	Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0	Preheat	-2.1	39	2.8	52.0
<b>Total</b>	<b>0.3</b>	<b>4.0</b>									ExFlr	0	Reheat	-1.7	89	52.0	70.0
											Roof	0	Humidif	0.0	0	0.0	0.0
											Wall	0	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	<b>Total</b>	<b>-3.8</b>			